

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1296:103

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Metal-Fab, P.O. Box 1138, Wichita, KS 67201
Contact: Jerold Jay (316) 943-4031

DESIGN: Model MSCD ceiling damper for horizontal mounting without ducts in exposed grids suspension system ceilings of fire resistive floor- or Roof-Ceiling designs. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as ceiling damper for use in fire resistive floor- or Roof-Ceiling designs rated up to 3 hour. For horizontal installations.

01-17-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**